

January 12, 2022

Delran Township School District
52 Hartford Road
Delran, NJ 08075

Dear Parents, Staff, Guardians,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Delran Township School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Delran Township School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Delran Township School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 179 samples taken throughout the District, 173 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Delran Township School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Delran High School Sink #5 – Room A-112 ID# 11-DHS-EC	97.6	Discontinue water use. Further investigation and confirmation testing will be conducted.
Delran Middle School Boiler Room – Point of Entry ID# 1-MS POE	15.9	Further investigation and confirmation testing will be conducted.
Delran Middle School Room D-175 - Fountain ID# 33-MS DW	435	Discontinue water use. Further investigation and confirmation testing will be conducted.

Delran Intermediate School Maintenance Office Point of Entry ID# 1-DIS-POE	197.0	Further investigation and confirmation testing will be conducted.
Millbridge Elementary Room 400 Fountain ID# 6-MB-DW	41.0	Discontinue water use. Further investigation and confirmation testing will be conducted.
Millbridge Elementary Kitchen Kettle Faucet ID# 16-MB-FB	68.6	Discontinue water use. Further investigation and confirmation testing will be conducted.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at <https://www.delranschools.org/> For more information about water quality in our schools, contact **Michael DiGiovanni** at the **Support Services, 856-461-1553 extension 5001**.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at **www.epa.gov/lead**, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Brian Brotschul, Ed. D
Superintendent of Schools



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Cathy Ledden
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

1/6/2022

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

BOE Pb Requirement Delran HS Initial

The reference number for these samples is EMSL Order #012115076. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
1-DHS-POE Boiler Rm POE		12/18/2021 6:00:00 AM	012115076-0001			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:34 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
2a-DHS-FP POU Sink #1 Kitchen		12/18/2021 6:01:00 AM	012115076-0002			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:38 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
2-DHS-IM Ice Machine Café		12/18/2021 6:02:00 AM	012115076-0003			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:39 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
3-DHS-FP Sink #2 Kitchen		12/18/2021 6:03:00 AM	012115076-0004			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:41 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
4-DHS-FP Sink #3 Kitchen		12/18/2021 6:04:00 AM	012115076-0005			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:42 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Clinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
5-DHS-FP Sink #4 Kitchen		12/18/2021 6:05:00 AM	012115076-0006			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
6-DHS-FP Food Prep Kettle Kitchen		12/18/2021 6:06:00 AM	012115076-0007			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	1.48	1.00 µg/L	1/4/2022	KB	1/4/2022 20:45 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
7-DHS-EC Sink #1 Rm A112 Food Lab		12/18/2021 6:07:00 AM	012115076-0008			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:50 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
8-DHS-EC Sink #2 Rm A112 Food Lab		12/18/2021 6:08:00 AM	012115076-0009			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:51 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
9-DHS-EC Sink #3 Rm A112 Food Lab		12/18/2021 6:09:00 AM	012115076-0010			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	1.25	1.00 µg/L	1/4/2022	KB	1/5/2022 14:35 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
10-DHS-EC Sink #4 Rm A112 Food Lab		12/18/2021 6:10:00 AM	012115076-0011		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.14	1.00 µg/L	1/4/2022 KB	1/5/2022 14:36 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
11-DHS-EC Sink #5 Rm A112 Food Lab		12/18/2021 6:11:00 AM	012115076-0012		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	97.6	1.00 µg/L	1/4/2022 KB	1/5/2022 14:38 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
12-DHS-EC Sink #6 Rm A112 Food Lab		12/18/2021 6:12:00 AM	012115076-0013		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.45	1.00 µg/L	1/4/2022 KB	1/5/2022 14:53 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
13-DHS-EC Sink #7 Rm A112 Food Lab		12/18/2021 6:13:00 AM	012115076-0014		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 14:41 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
14-DHS-DW Sink Rm A-110		12/18/2021 6:14:00 AM	012115076-0015		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 14:42 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
17-DHS-DW Sink Rm 115		12/18/2021 6:15:00 AM	012115076-0016		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.84	1.00 µg/L	1/4/2022 KB	1/5/2022 14:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
18-DHS-WC Fount. R Hall Near Main Entrance		12/18/2021 6:16:00 AM	012115076-0017		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 14:54 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
19-DHS-WC Fount. L Hall Near Main Entrance		12/18/2021 6:17:00 AM	012115076-0018		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 14:58 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
20-DHS-DW Sink Main Office		12/18/2021 6:18:00 AM	012115076-0019		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.20	1.00 µg/L	1/4/2022 KB	1/5/2022 15:00 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
21-DHS-NS Sink Nurse Office		12/18/2021 6:19:00 AM	012115076-0020		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.60	1.00 µg/L	1/4/2022 KB	1/5/2022 15:01 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
23-DHS-DW Bottle Filler Hall Near B109		12/18/2021 6:20:00 AM	012115076-0021			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 15:03 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
24-DHS-DW Sink Rm B109		12/18/2021 6:21:00 AM	012115076-0022			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	7.68	1.00 µg/L	1/4/2022	KB	1/5/2022 15:04 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
25-DHS-DW Sink Library		12/18/2021 6:22:00 AM	012115076-0023			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 21:31 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
26-DHS-TL Sink Teachers Lounge		12/18/2021 6:23:00 AM	012115076-0024			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	2.70	1.00 µg/L	1/4/2022	KB	1/4/2022 21:32 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
28-DHS-DW Bottle Filler Hall Near Boys Locker Rm		12/18/2021 6:24:00 AM	012115076-0025			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 21:34 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
30-DHS-DW Fountain Girls Locker Rm		12/18/2021 6:26:00 AM	012115076-0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.27	1.00 µg/L	1/4/2022 KB	1/4/2022 21:35 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
31-DHS-DW Wall Tap Faucet Trainers Office		12/18/2021 6:27:00 AM	012115076-0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:37 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
32-DHS-IM Ice Machine Trainers Rm		12/18/2021 6:28:00 AM	012115076-0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 14:19 JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
33-DHS-DW Fount. #1 Outside of Trainers Rm		12/18/2021 6:29:00 AM	012115076-0029		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:41 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
34-DHS-DW Fount. #2 Outside of Trainers Rm		12/18/2021 6:30:00 AM	012115076-0030		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:43 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
35-DHS-DW Fount. #3 Outside of Trainers Rm		12/18/2021 6:31:00 AM		012115076-0031	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
36-DHS-DW Fount. #4 Outside of Trainers Rm		12/18/2021 6:32:00 AM		012115076-0032	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:49 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
37-DHS-DW Fount. #5 Outside of Trainers Rm		12/18/2021 6:33:00 AM		012115076-0033	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:50 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
39-DHS-DW Bottle Filler Hall Near Rm 222		12/18/2021 6:34:00 AM		012115076-0034	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:52 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
41-DHS-DW Bottle Filler Hall Near 205		12/18/2021 6:35:00 AM		012115076-0035	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 21:53 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012115076
CustomerID:	COAS80
CustomerPO:	
ProjectID:	

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
42-DHS-WC Fount L Hall Near S146		12/18/2021 6:36:00 AM		012115076-0036			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 21:54	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
43-DHS-WC Fount R Hall Near S146		12/18/2021 6:37:00 AM		012115076-0037			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:09	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
44-DHS-WC Fount L Hall Near S240		12/18/2021 6:38:00 AM		012115076-0038			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:10	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
45-DHS-WC Fount R Hall Near S240		12/18/2021 6:39:00 AM		012115076-0039			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:11	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
Blank		12/18/2021		012115076-0040			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:13	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115076
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran HS Initial**

Analytical Results

Client Sample Description 46-DHS-WC **Collected:** 12/18/2021 **Lab ID:** 012115076-0041
 Fountain L Rm 124 6:40:00 AM

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:14	KB

Client Sample Description 46A-DHS-WC **Collected:** 12/18/2021 **Lab ID:** 012115076-0042
 Fountain R Rm 124 6:41:00 AM

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/4/2022 20:16	KB

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Cathy Ledden
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

1/6/2022

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

Delran Intermediate School - Initial

The reference number for these samples is EMSL Order #012115071. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
1-DIS-POE POE Maintenance Office		12/18/2021 7:30:00 AM	012115071-0001			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	197 D	5.00 µg/L	1/4/2022	KB	1/5/2022 15:29 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
2-DIS-POU Fountain Café		12/18/2021 7:31:00 AM	012115071-0002			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 15:32 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
3-DIS-IM Ice Machine Café		12/18/2021 7:32:00 AM	012115071-0003			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 15:34 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
4-DIS-FP Sink 1 Kitchen		12/18/2021 7:33:00 AM	012115071-0004			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 15:35 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
5-DIS-FP Sink 2 Kitchen		12/18/2021 7:34:00 AM	012115071-0005			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 15:37 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
6-DIS-FP Sink 3 Kitchen		12/18/2021 7:35:00 AM	012115071-0006		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:38 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
7-DIS-FP Sink 4 Kitchen		12/18/2021 7:36:00 AM	012115071-0007		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.33	1.00 µg/L	1/4/2022 KB	1/5/2022 15:43 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
7A-DIS-ST Steamer Kitchen		12/18/2021 7:37:00 AM	012115071-0008		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
8-DIS-DW Sink Rm 604		12/18/2021 7:38:00 AM	012115071-0009		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:46 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
9-DIS-DW Sink L Rm 602		12/18/2021 7:39:00 AM	012115071-0010		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:47 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
10-DIS-DW Sink R Rm 602		12/18/2021 7:40:00 AM	012115071-0011		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:49 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
11-DIS-WC Fount L Hall near 602		12/18/2021 7:41:00 AM	012115071-0012		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:53 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
12-DIS-WC Fount R Hall near 602		12/18/2021 7:42:00 AM	012115071-0013		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.13	1.00 µg/L	1/4/2022 KB	1/5/2022 07:54 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
13-DIS-DW Fount Rm 503		12/18/2021 7:43:00 AM	012115071-0014		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:56 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
14-DIS-DW Fount Rm 504		12/18/2021 7:44:00 AM	012115071-0015		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:57 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
15-DIS-DW Fount Rm 505		12/18/2021 7:45:00 AM	012115071-0016		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:58 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
16-DIS-DW Fount Rm 506		12/18/2021 7:46:00 AM	012115071-0017		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:00 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
17-DIS-DW Fount Rm 507		12/18/2021 7:47:00 AM	012115071-0018		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:01 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
18-DIS-DW Fount Rm 508		12/18/2021 7:48:00 AM	012115071-0019		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:03 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
19-DIS-DW Fount Rm 509		12/18/2021 7:49:00 AM	012115071-0020		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:07 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: Delran Intermediate School - Initial

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
20-DIS-DW Fount Rm 510		12/18/2021 7:50:00 AM	012115071-0021		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:39 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
21-DIS-DW Fount Rm 511		12/18/2021 7:51:00 AM	012115071-0022		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:43 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
22-DIS-DW Fount Rm 512		12/18/2021 7:52:00 AM	012115071-0023		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:45 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
23-DIS-TL Sink Faculty Rm		12/18/2021 7:53:00 AM	012115071-0024		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:46 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
24-DIS-WC Fount L Hall near Multi Purpose		12/18/2021 7:54:00 AM	012115071-0025		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:48 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
25-DIS-WC Fount R Hall near Multi Purpose		12/18/2021 7:55:00 AM	012115071-0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:49 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
26-DIS-DW Fount Rm 403		12/18/2021 7:56:00 AM	012115071-0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:51 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
27-DIS-DW Fount Rm 404		12/18/2021 7:57:00 AM	012115071-0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:52 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
28-DIS-DW Fount Rm 405		12/18/2021 7:58:00 AM	012115071-0029		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:57 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
29-DIS-DW Fount Rm 406		12/18/2021 7:59:00 AM	012115071-0030		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 06:58 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
30-DIS-DW Fount Rm 407		12/18/2021 8:00:00 AM	012115071-0031		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:00 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
31-DIS-DW Fount Rm 408		12/18/2021 8:01:00 AM	012115071-0032		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:04 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
32-DIS-DW Fount Rm 409		12/18/2021 8:02:00 AM	012115071-0033		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:05 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
33-DIS-DW Fount Rm 410		12/18/2021 8:03:00 AM	012115071-0034		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:07 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
34-DIS-DW Fount Rm 411		12/18/2021 8:04:00 AM	012115071-0035		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:08 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
35-DIS-DW Fount Rm 412		12/18/2021 8:05:00 AM	012115071-0036		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 07:10 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
36-DIS-DW rm 610 Library Media Sink		12/18/2021 8:06:00 AM	012115071-0037		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:13 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
37-DIS-DW Main Office - Sink		12/18/2021 8:07:00 AM	012115071-0038		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:14 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
38-DIS-WC Fountain Main Office		12/18/2021 8:08:00 AM	012115071-0039		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:16 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
39-DIS-DW Nurse Office - Sink		12/18/2021 8:09:00 AM	012115071-0040		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 15:17 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
40-DIS-WC Hall Near Nurse Fount R		12/18/2021 8:10:00 AM	012115071-0041			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 08:27 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
41-DIS-WC Hall Near Nurse Fount L		12/18/2021 8:11:00 AM	012115071-0042			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 08:28 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
42-DIS-DW Rm 303 Fountain		12/18/2021 8:12:00 AM	012115071-0043			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 08:29 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
43-DIS-DW Rm 304 Fountain		12/18/2021 8:13:00 AM	012115071-0044			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 08:31 KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>		
44-DIS-DW Rm 305 Fountain		12/18/2021 8:14:00 AM	012115071-0045			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>
METALS						
200.8	Lead	ND	1.00 µg/L	1/4/2022	KB	1/5/2022 08:32 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: Delran Intermediate School - Initial

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
45-DIS-DW Rm 306 Fountain		12/18/2021 8:15:00 AM	012115071-0046		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:34 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
46-DIS-DW Rm 307 Fountain		12/18/2021 8:16:00 AM	012115071-0047		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:38 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
47-DIS-DW Rm 308 Fountain		12/18/2021 8:17:00 AM	012115071-0048		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:43 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
48-DIS-DW Rm 309 Fountain		12/18/2021 8:18:00 AM	012115071-0049		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
49-DIS-DW Rm 310 Fountain		12/18/2021 8:19:00 AM	012115071-0050		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:46 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115071
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **Delran Intermediate School - Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
50-DIS-DW Rm 311 Fountain		12/18/2021 8:20:00 AM	012115071-0051		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:47 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
51-DIS-DW Rm 312 Fountain		12/18/2021 8:21:00 AM	012115071-0052		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:49 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
BLANK		12/18/2021	012115071-0053		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:50 KB

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Cathy Ledden
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

1/4/2022

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

BOE Pb Requirement Delran Middle School Initial

The reference number for these samples is EMSL Order #012114848. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012114848
CustomerID:	COAS80
CustomerPO:	
ProjectID:	

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
1-MS POE Boiler Room POE		12/18/2021 8:40:00 AM	012114848-0001		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	15.9	1.00 µg/L	12/29/2021 JD	12/30/2021 JW 15:03
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
2-MS DW/POE Faculty Room Women's Bathroom Sink left		12/18/2021 8:41:00 AM	012114848-0002		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.68	1.00 µg/L	1/3/2022 KB	1/3/2022 23:24 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
3-MS TL Faculty Room-Sink		12/18/2021 8:42:00 AM	012114848-0003		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:28 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
4-MS IM Kitchen- Ice Machine		12/18/2021 8:43:00 AM	012114848-0004		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	12/29/2021 JD	12/30/2021 JW 15:09
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
5-MS FP Kitchen Sink #1		12/18/2021 8:44:00 AM	012114848-0005		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:30 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114848
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
6-MS FP Kitchen Sink #2		12/18/2021 8:45:00 AM	012114848-0006				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/3/2022	KB	1/3/2022 23:31	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
7-MS FP Kitchen Food Prep Kettle		12/18/2021 8:46:00 AM	012114848-0007				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.10	1.00 µg/L	1/3/2022	KB	1/3/2022 23:33	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
8-MS FP Kitchen Sink #3		12/18/2021 8:47:00 AM	012114848-0008				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	ND	1.00 µg/L	1/3/2022	KB	1/3/2022 23:37	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
9-MS FP Kitchen Sink #4		12/18/2021 8:48:00 AM	012114848-0009				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	1.02	1.00 µg/L	1/3/2022	KB	1/3/2022 23:38	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>			
10-MS FP Kitchen Sink #5		12/18/2021 8:49:00 AM	012114848-0010				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>		<i>Analysis Date & Analyst</i>	
METALS							
200.8	Lead	7.33	1.00 µg/L	1/3/2022	KB	1/3/2022 23:40	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114848
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
11-MS FP Kitchen Sink #6		12/18/2021 8:50:00 AM	012114848-0011		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:41 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
12-MS DW Hall Near Cafeteria L Fountain		12/18/2021 8:51:00 AM	012114848-0012		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.12	1.00 µg/L	1/3/2022 KB	1/3/2022 23:43 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
13-MS DW Hall Near Cafeteria R Fountain		12/18/2021 8:52:00 AM	012114848-0013		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.03	1.00 µg/L	1/3/2022 KB	1/3/2022 23:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
14-MS WC Hall Near Girls Gym Bottle Filler		12/18/2021 8:53:00 AM	012114848-0014		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:49 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
16-MS DW Fountain Gym		12/18/2021 8:55:00 AM	012114848-0015		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:50 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114848
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
17-MS WC C-108 Woodshop Fountain		12/18/2021 8:56:00 AM	012114848-0016		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:55 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
18-MS WC Hall Near C115 Fountain		12/18/2021 8:57:00 AM	012114848-0017		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/3/2022 23:56 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
19-MS EC Room C115 Sink #1		12/18/2021 8:58:00 AM	012114848-0018		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	6.18	1.00 µg/L	1/3/2022 KB	1/3/2022 23:58 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
20-MS EC Room C115 Sink #2		12/18/2021 8:59:00 AM	012114848-0019		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	8.98	1.00 µg/L	1/3/2022 KB	1/3/2022 23:59 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
21-MS EC Room C115 Sink #3		12/18/2021 9:00:00 AM	012114848-0020		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.16	1.00 µg/L	1/3/2022 KB	1/4/2022 00:00 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114848
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
22-MS EC Room C115 Sink #4		12/18/2021 9:01:00 AM	012114848-0021		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.18	1.00 µg/L	1/3/2022 KB	1/4/2022 00:02 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
23-MS EC Room C115 Sink #5		12/18/2021 9:02:00 AM	012114848-0022		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.50	1.00 µg/L	1/3/2022 KB	1/4/2022 00:03 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
24-MS EC Room C115 Sink #6		12/18/2021 9:03:00 AM	012114848-0023		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.85	1.00 µg/L	1/3/2022 KB	1/4/2022 01:01 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
25-MS WC Library Fountain		12/18/2021 9:04:00 AM	012114848-0024		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/4/2022 12:02 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
26-MS-DW Main Office Bathroom Sink		12/18/2021 9:05:00 AM	012114848-0025		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.00	1.00 µg/L	1/3/2022 KB	1/4/2022 12:04 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012114848
CustomerID:	COAS80
CustomerPO:	
ProjectID:	

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
27-MS-NS Nurse Sink		12/18/2021 9:06:00 AM	012114848-0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/4/2022 12:05 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
28-MS-WC Hall Near Nurse Bottle Filler		12/18/2021 9:07:00 AM	012114848-0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/4/2022 12:07 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
29-MS DW Room B-143 Fountain		12/18/2021 9:08:00 AM	012114848-0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.63	1.00 µg/L	1/3/2022 KB	1/4/2022 12:08 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
30-MS DW Room B-152 Fountain		12/18/2021 9:09:00 AM	012114848-0029		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.06	1.00 µg/L	1/3/2022 KB	1/4/2022 12:13 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
32-MS DW Room D-174 Fountain		12/18/2021 9:11:00 AM	012114848-0030		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	9.63	1.00 µg/L	1/3/2022 KB	1/4/2022 12:14 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114848
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Middle School Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
33-MS DW Room D-175		12/18/2021 9:12:00 AM	012114848-0031		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	435 D	10.0 µg/L	1/3/2022 KB	1/4/2022 12:16 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
34-MS DW Hall Near D160-R Fountain		12/18/2021 9:13:00 AM	012114848-0032		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/4/2022 12:18 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
35-MS DW Hall Near D160-L Fountain		12/18/2021 9:14:00 AM	012114848-0033		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/4/2022 12:20 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
BLANK		12/18/2021	012114848-0034		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/3/2022 KB	1/4/2022 12:24 KB

Definitions:

MDL - method detection limit
 J - Result was below the reporting limit, but at or above the MDL
 ND - indicates that the analyte was not detected at the reporting limit
 RL - Reporting Limit (Analytical)
 D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

C Leddew
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

1/7/2022

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

BOE Pb Requirement - Delran Millbridge Elementary Initial

The reference number for these samples is EMSL Order #012114911. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-8197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
1-MB-POE Boiler Room POE		12/18/2021 9:30:00 AM	012114911-0001		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:10 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
2-MB-DW/POU Hall Near Maintenance Office Fountain		12/18/2021 9:31:00 AM	012114911-0002		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.00	1.00 µg/L	1/4/2022 KB	1/5/2022 04:17 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
3-MB-DW Main Office Copy Room-Sink		12/18/2021 9:32:00 AM	012114911-0003		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:19 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
4-MB-TL Faculty Room-Sink		12/18/2021 9:33:00 AM	012114911-0004		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:20 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
6-MB-DW Room 400 Fountain		12/18/2021 9:34:00 AM	012114911-0005		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	41.0	1.00 µg/L	1/4/2022 KB	1/5/2022 04:22 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Ledded**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
7-MB-DW Room 401 Fountain		12/18/2021 9:35:00 AM	012114911-0006		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:23 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
8-MB-DW Hall Near 401-Bottle Filler		12/18/2021 9:36:00 AM	012114911-0007		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:25 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
9-MB-DW Room 402 Fountain		12/18/2021 9:37:00 AM	012114911-0008		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.03	1.00 µg/L	1/4/2022 KB	1/5/2022 04:26 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
12-MB-DW Room 403 Fountain		12/18/2021 9:40:00 AM	012114911-0009		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.20	1.00 µg/L	1/4/2022 KB	1/5/2022 04:28 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
13-MB-DW Room 404 Fountain		12/18/2021 9:41:00 AM	012114911-0010		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:29 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
14-MB-DW Room 405 Fountain		12/18/2021 9:42:00 AM	012114911-0011		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:31 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
15-MB-FP Kitchen Sink #1 Sink		12/18/2021 9:43:00 AM	012114911-0012		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:38 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
16-MB-FP Kitchen Food Prep Kettle Faucet		12/18/2021 9:44:00 AM	012114911-0013		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	68.6	1.00 µg/L	1/5/2022 KB	1/6/2022 17:37 JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
17-MB-IM Ice Machine Cafeteria		12/18/2021 9:45:00 AM	012114911-0014		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/5/2022 KB	1/6/2022 17:24 JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
21-MB-DW Room 300 Fountain		12/18/2021 9:48:00 AM	012114911-0015		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	4.68	1.00 µg/L	1/4/2022 KB	1/5/2022 04:40 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
22-MB-DW Room 301 Fountain		12/18/2021 9:49:00 AM	012114911-0016		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.53	1.00 µg/L	1/4/2022 KB	1/5/2022 04:41 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
23-MB-DW Room 302 Fountain		12/18/2021 9:50:00 AM	012114911-0017		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.05	1.00 µg/L	1/4/2022 KB	1/5/2022 04:42 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
24-MB-DW Room 303 Fountain		12/18/2021 9:51:00 AM	012114911-0018		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.14	1.00 µg/L	1/4/2022 KB	1/5/2022 04:44 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
25-MB-DW Room 304 Fountain		12/18/2021 9:52:00 AM	012114911-0019		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	9.81	1.00 µg/L	1/5/2022 KB	1/6/2022 17:31 JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
26-MB-DW Room 305 Fountain		12/18/2021 9:53:00 AM	012114911-0020		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:45 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
27-MB-DW Room 306 Fountain		12/18/2021 9:54:00 AM	012114911-0021		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:47 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
28-MB-DW Room 307 Fountain		12/18/2021 9:55:00 AM	012114911-0022		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:48 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
29-MB-DW Room 308 Fountain		12/18/2021 9:56:00 AM	012114911-0023		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.09	1.00 µg/L	1/4/2022 KB	1/5/2022 04:53 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
30-MB-DW Room 309 Fountain		12/18/2021 9:57:00 AM	012114911-0024		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 04:59 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
31-MB-NS Room A05 Nurse Sink		12/18/2021 9:58:00 AM	012114911-0025		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.96	1.00 µg/L	1/4/2022 KB	1/5/2022 05:03 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
32-MB-DW Room 200 Fountain		12/18/2021 9:59:00 AM	012114911-0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.05	1.00 µg/L	1/4/2022 KB	1/5/2022 05:05 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
33-MB-DW Room 201 Fountain		12/18/2021 10:00:00 AM	012114911-0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.60	1.00 µg/L	1/4/2022 KB	1/5/2022 05:06 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
34-MB-DW Room 202 Fountain		12/18/2021 10:01:00 AM	012114911-0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	10.2	1.00 µg/L	1/4/2022 KB	1/5/2022 05:10 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
35-MB-DW Room 203 Fountain		12/18/2021 10:02:00 AM	012114911-0029		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.63	1.00 µg/L	1/5/2022 KB	1/6/2022 17:33 JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
36-MB-DW Room 204 Fountain		12/18/2021 10:03:00 AM	012114911-0030		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.60	1.00 µg/L	1/5/2022 KB	1/6/2022 17:35 JW

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012114911
CustomerID:	COAS80
CustomerPO:	
ProjectID:	

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
37-MB-DW Room 205 Fountain		12/18/2021 10:04:00 AM	012114911-0031		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.15	1.00 µg/L	1/4/2022 KB	1/5/2022 05:12 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
38-MB-DW Hall Near 206 Fountain		12/18/2021 10:05:00 AM	012114911-0032		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.34	1.00 µg/L	1/4/2022 KB	1/5/2022 05:13 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
39-MB-DW Room 206 Fountain		12/18/2021 10:06:00 AM	012114911-0033		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.95	1.00 µg/L	1/5/2022 KB	1/6/2022 17:46 JW
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
40-MB-DW Room 207 Fountain		12/18/2021 10:07:00 AM	012114911-0034		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.76	1.00 µg/L	1/4/2022 KB	1/5/2022 05:15 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
41-MB-DW Room 208 Fountain		12/18/2021 10:08:00 AM	012114911-0035		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.22	1.00 µg/L	1/4/2022 KB	1/5/2022 05:16 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
42-MB-DW Room 209 Fountain		12/18/2021 10:09:00 AM	012114911-0036		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.27	1.00 µg/L	1/4/2022 KB	1/5/2022 05:18 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
43-MB-DW Room 210 Fountain		12/18/2021 10:10:00 AM	012114911-0037		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.93	1.00 µg/L	1/4/2022 KB	1/5/2022 05:19 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
44-MB-DW Room 211 Fountain		12/18/2021 10:11:00 AM	012114911-0038		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 05:24 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
44A-MB-DW Hall Near 211 Fountain		12/18/2021 10:12:00 AM	012114911-0039		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	8.83	1.00 µg/L	1/4/2022 KB	1/5/2022 05:31 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
45-MB-DW Room 212 Fountain		12/18/2021 10:13:00 AM	012114911-0040		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.18	1.00 µg/L	1/4/2022 KB	1/5/2022 05:33 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
46-MB-DW Room 100 Fountain		12/18/2021 10:14:00 AM	012114911-0041		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.02	1.00 µg/L	1/4/2022 KB	1/5/2022 05:34 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
47-MB-DW Room 101 Fountain		12/18/2021 10:15:00 AM	012114911-0042		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 05:35 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
48-MB-DW Room 102 Fountain		12/18/2021 10:16:00 AM	012114911-0043		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 05:37 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
49-MB-DW Room 104 Fountain		12/18/2021 10:17:00 AM	012114911-0044		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.23	1.00 µg/L	1/4/2022 KB	1/5/2022 05:38 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
50-MB-DW Room 103 Fountain		12/18/2021 10:18:00 AM	012114911-0045		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 05:40 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012114911
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
51-MB-DW Room 106 Fountain		12/18/2021 10:19:00 AM	012114911-0046		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 05:41 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
52-MB-DW Room 105 Fountain		12/18/2021 10:20:00 AM	012114911-0047		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:13 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
53-MB-DW Room 108 Fountain		12/18/2021 10:21:00 AM	012114911-0048		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:18 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
54-MB-DW Room 107 Fountain		12/18/2021 10:22:00 AM	012114911-0049		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:19 KB
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
55-MB-DW Room 110 Fountain		12/18/2021 10:23:00 AM	012114911-0050		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:21 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012114911
CustomerID:	COAS80
CustomerPO:	
ProjectID:	

Attn: **C Leddew**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement - Delran Millbridge Elementary Initial**

Analytical Results

Client Sample Description	BLANK BLANK	Collected:	12/18/2021	Lab ID:	012114911-0051
----------------------------------	----------------	-------------------	------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/5/2022 08:25 KB

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Cathy Ledden
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

1/5/2022

Phone: (609) 820-9312

Fax: (609) 561-6197

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/20/2021. The results are tabulated on the attached data pages for the following client designated project:

BOE Pb Requirement Delran Board of Ed.

The reference number for these samples is EMSL Order #012115075. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012115075
 CustomerID: COAS80
 CustomerPO:
 ProjectID:

Attn: **Cathy Ledden**
Coastal Environmental Compliance, LLC
PO Box 167
Hammonton, NJ 08037-0167

Phone: (609) 820-9312
 Fax: (609) 561-6197
 Received: 12/20/2021 09:00 AM

Project: **BOE Pb Requirement Delran Board of Ed.**

Analytical Results

Client Sample Description 1 BOE - POE
 Mechanical Rm POE
Collected: 12/18/2021 6:45:00 AM
Lab ID: 012115075-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.91	1.00 µg/L	1/4/2022 KB	1/4/2022 20:25 KB

Client Sample Description 2 BOE DW/POU
 Sink Work Rm
Collected: 12/18/2021 6:46:00 AM
Lab ID: 012115075-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	1/4/2022 KB	1/4/2022 20:29 KB

Client Sample Description 3 BOE - WC
 Fountain Entry Hall
Collected: 12/18/2021 6:47:00 AM
Lab ID: 012115075-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.61	1.00 µg/L	1/4/2022 KB	1/4/2022 20:31 KB

Client Sample Description Blank
Collected: 12/18/2021
Lab ID: 012115075-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	1/4/2022 KB	1/4/2022 20:32 KB

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results